



June 9, 2005

To the attention of: Mr. Frank Borrelli

RE: The use of Lead in NSF Certified products

Dear Mr. Borrelli,

I am writing this letter to you in order to outline NSF requirement and policy concerning the use of lead in the NSF certified products.

This requirement has been established in NSF General Policy **GP – 60** that indicates: *“There shall be no lead as an intentional ingredient in any material contacting food or drinking water, except brass meeting the definition of “lead free” under the specific provisions of the Safe Drinking Water Act of the United States, as amended in 1986. In the absence of further regulatory guidance, the EPA Action Level of 15 ppb shall be used for purposes of establishing the maximum extraction levels for Products contacting food or drinking water”.*

If you have any further questions, please do not hesitate to contact me.

Sincerely,

Nasrin Kashefi

Nasrin Kashefi
Manager, Plumbing Programs
NSF International

Phone: (734) 913-5743
Fax: (734) 827-7174
e-mail: kashefi@nsf.org